SIEMENS

Data sheet 6GK1561-2AA00

product type designation



CP 5612

Communications processor CP 5612 PCI card for connection connection of a PG or PC with PCI bus to PROFIBUS or MPI usable in 32 bit and 64 bit operating systems see also entry ID 22611503.

transfer rate		
transfer rate		
 at the 1st interface / according to PROFIBUS 	9.6 kbit/s 12 Mbit/s	
interfaces		
number of electrical connections		
 at the 1st interface / according to PROFIBUS 	1	
type of electrical connection		
 at the 1st interface / according to PROFIBUS 	9-pin Sub-D socket (RS 485)	
 of the backplane bus 	PCI (32Bit 3,3V/5V UniversalKey 33/66MHz)	
supply voltage, current consumption, power loss		
type of voltage / of the supply voltage	DC	
supply voltage		
 1 / from backplane bus 	3.3 V	
2 / from backplane bus	12 V	
relative symmetrical tolerance / at DC		
• at 3.3 V	9 %	
● at 12 V	8 %	
consumed current		
1 / from backplane bus / at DC / maximum	0.15 A	
• 2 / from backplane bus / at DC / maximum	0.25 A	
power loss [W]	3.5 W	
ambient conditions		
ambient temperature		
 during operation 	5 55 °C	
during storage	-20 +60 °C	
during transport	-20 +60 °C	
relative humidity / at 25 °C / without condensation / during operation / maximum	95 %	
protection class IP	IP00	
design, dimensions and weights		
module format	PCI	
width	18 mm	
height	107 mm	
depth	125 mm	
net weight	98 g	
product features, product functions, product components / general		
number of plug-in cards of same design / plug-in / per PC station	1	
number of units / note		

performance data / open communication	
software / for open communication / by means of	Yes, SOFTNET-PB DP / SOFTNET-PB DP Slave / SOFTNET-PB S7
SEND/RECEIVE / required number of possible connections / for open communication / by	50
means of SEND/RECEIVE / maximum	
performance data / PROFIBUS DP	V. COSTANT DD DD
software / for DP master function / required	Yes, SOFTNET-PB DP
service / as DP master	
• DPV0	Yes
• DPV1	Yes
DPV2 Turnbox of DD clause / on DD master / one roble	No 64
number of DP slaves / on DP master / operable data volume	04
of the address range of the inputs / as DP master / total	14640 byte
of the address range of the inputs / as DP master / total of the address range of the outputs / as DP master / total	14640 byte
of the address range of the inputs / per DP slave	244 byte
of the address range of the outputs / per DP slave	244 byte
of the address range of the diagnostic data / per DP slave	244 byte
software / for DP slave function / required	Yes, SOFTNET-PB DP slave
service / as DP slave	100, 001
• DPV0	Yes
• DPV1	No
data volume	
 of the address range of the inputs / as DP slave / total 	122 byte
 of the address range of the outputs / as DP slave / total 	122 byte
performance data / S7 communication	
software / for S7 communication / required	Yes, SOFTNET-PB S7
number of possible connections / for S7/PG communication / maximum	8
performance data / multi-protocol mode	
number of configurable connections / per PC station	207
product functions / management, configuration, engineering	
configuration software / required	Included in the scope of delivery of the required software product
product functions / diagnostics	
product function	
port diagnostics	Yes
standards, specifications, approvals	
reference code	
• according to IEC 81346-2:2019	KEC
standards, specifications, approvals / Environmental Product Do	
Environmental Product Declaration	Yes
Global Warming Potential [CO2 eq]	
• total	129.61 kg
during manufacturing	33.23 kg
during operation	96.32 kg
after end of life	0.06 kg
accessories	anti-analy MDI and In
accessories	optional: MPI cable
further information / internet links	
internet link	https://gupport.industry.giomera.gov/selven/artifect/400700050
to website: Selection guide for cables and connectors to web page: selection guid TIA Selection Teel	https://support.industry.siemens.com/cs/ww/en/view/109766358
to web page: selection aid TIA Selection Tool to website: Industrial communication	https://www.siemens.com/tstcloud
to website: Industrial communication to web page: SigPortal	https://www.siemens.com/simatic-net https://sieportal.siemens.com/
to web page: SiePortal to website: Image database	
to website: Image database to website: CAy Download Manager	https://www.siemens.com/bilddb
to website: CAx-Download-Manager to website: Industry Online Support	https://www.siemens.com/cax
to website: Industry Online Support security information	https://support.industry.siemens.com
	Signate provides products and solutions with industrial subgressourity functions
security information	Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic,

state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)

Approvals / Certificates

General Product Approval

Declaration of Conformity











EMV Environment

KC Confirmation



last modified: 8/8/2024 🖸