SIEMENS

Data sheet

6EP4346-7RB00-0AX0



SITOP RED1200/Red.M./DC24/48V/2X10A

SITOP RED1200 redundancy module Input/output: 24/48 V DC/20 A Suitable for decoupling two SITOP power supplies with max. 10 A output current each

input		
type of the power supply network	DC voltage	
supply voltage at DC	12 48 V	
input voltage at DC	10 58 V	
output		
voltage curve at output	Controlled DC voltage	
number of outputs	1	
output voltage at DC rated value	24 V	
formula for output voltage	Vin - approx. 0.6 V	
output voltage		
 at output 1 at DC rated value 	24 V	
output voltage adjustable	No	
output current		
rated value	20 A	
bridging of equipment	No	
efficiency		
efficiency in percent	97.5 %	
power loss [W]		
 at rated output voltage for rated value of the output current typical 	12 W	
 during no-load operation maximum 	0.1 W	
safety		
galvanic isolation between input and output	No	
operating resource protection class	Class III	
protection class IP	IP20	
standard		
 for emitted interference 	EN 61000-6-3	
 for interference immunity 	EN 61000-6-2	
standards, specifications, approvals		
certificate of suitability		
CE marking	Yes	
UL approval	Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259	
CSA approval	Yes; CSA C22.2 No. 62368-1	
NEC Class 2	No	
MTBF at 40 °C	8 100 000 h	
standards, specifications, approvals hazardous environments		
certificate of suitability		
• IECEx	No	
• ATEX	No	
ULhazloc approval	No	

mperature +25 °C (unless
inportatione - 20 O (diffiess
strial cybersecurity functions
a, machines and networks. etworks against cyber usly maintain – a holistic, mens' products and Customers are responsible systems, machines and s should only be connected extent such a connection is sures (e.g. firewalls and/or nformation on industrial please visit ' products and solutions re secure. Siemens strongly pon as they are available
a, machines etworks ag usly mainta Customers cystems, m s should or extent suc sures (e.g. nformation please visit ' products : re secure.

and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)

Classifications							
				Version	Classification		
			eClass	14	27-04-07-01		
			eClass	12	27-04-07-01		
			eClass	9.1	27-04-07-01		
			eClass	9	27-04-07-01		
			eClass	8	27-04-90-02		
			eClass	7.1	27-04-90-02		
			eClass	6	27-04-90-02		
			ETIM	9	EC002540		
			ETIM	8	EC002540		
			ETIM	7	EC002540		
			IDEA	4	4130		
			UNSPSC	15	39-12-10-04		
pprovals Certificates							
General Product Appr	roval						
СВ	(SP)	<u>Manufacturer De</u> tion	clara- <u>Declaration of Con-</u> formity	CE EG-Konf.	UK CA		
General Product Approval	Marine / Shipping	Environment					
	ABS	EPD					
last modified:		6/26/2024 🖸					